



FIRE TEST REPORT INFORMATION

Classic Integra

Vantt 2500

Roll-up Aluminium Matting

For your information, please also find a link to our 'White Paper' containing some explanatory information pertaining to Fire Resistance, and covering off the details for the requirements of the NCC 2019 and Fire Resistance of Floor Coverings.

Class 2 - 9 Properties of Floor Material and Coverings

Specification C1.10 of the NCC 2019 states that a floor lining or floor covering must have:

- a) a Critical Radiant Flux (CRF) not less than that listed in the Table 2; and
- in a building not protected by a sprinkler system (other than a FPAA101D or FPAA101H system) complying with <u>Specification E1.5</u>, a maximum <u>smoke development rate</u> of 750 percent-minutes; and
- c) a group number complying with <u>Clause 6(b)</u>, for any portion of the floor covering that is continued more than 150 mm up a wall.

For the Classic Integra Vantt 2500 product, the fire test properties are:

- Critical Radiant Flux is 1.4 kW/m2
- Smoke Development Rate is 883 %/min.

A copy of the Fire Test report is on the following page.

Please also feel free to download a copy of any of our Product Data Sheets from the website.

Please note Classic Architectural Group are not licensed Building Surveyors, nor do we in any way purport to be. We strongly recommend that you have this product verified by an accredited party that it is fit for its intended application before installation.



For Every Step

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racocourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Classic Architectural Group Pty Ltd

6 Beaufort Street Preston Vic 3072 Test Number :

17-002470

Issue Date Print Date 05/06/2017

Order Number :

39622

Sample Description

Clients Ref:

"Integra Vantt 2500 Series Entrance matting, with ribbed carpet matting insert"

Semi-flexible assembly of aluminuim frames with polypropylene carpet, color - Charcoal

6700g/m2

Nominal Mass per Unit Area/Density:

Nominal Thickness:

10 mm

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 18/05/2017 Date Tested 05/06/2017 CHF Value 2 3 4 Mean Length 1.4 1.2 1.6 1.4 kW/m3 Width 1.5 - kW/m² Smoke Value 1 2 3 Mean Length 886 989 875 883 % min Width 878 - % min

Melting Yes
Blistering Yes

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive, and clamped prior to testing.

26139

5017

Page 1 of 1

) Assiration Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 1702
- Chemical Testing

Mechanical Testing Performance & Approvals Testing : Accreditation No. : Accreditation No. : Accreditation No.

960 1356

JACKSON B.Sc.(Hors) SING DIRECTOR

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, legited or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Otrector of AWTA Ltd.

2001

APPROVED SIGNATORY

0204/11/06