



**classic**  
architectural group



**For Every Step**

## **SLIP REPORT INFORMATION**

Classic Tredfx

**PKD443**

Aluminium Safety Stair Nosing for Carpet Applications

For your information regarding Slip Resistance Requirement for stairs and landings and ramps, the requirement for slip resistance of stairs and landings can be found in both Australian Standard AS4586, and HB 198:2014 'Guide to the specification and testing of slip resistance of pedestrian surfaces' Table 3A as follows:

"Stair treads and Stairway landings, and Ramps in buildings covered by NCC Volumes One and Two"

...Dry Stair tread, a stair non-skid nosing strip and a stairway landing; Ramps not steeper than 1:14 gradient (when dry) -  
The suggested minimum Wet Pendulum result is **Class P3**

...Wet Stair tread, a stair non-skid nosing strip and a stairway landing; Ramps not steeper than 1:14 gradient (when wet) -  
The suggested minimum Wet Pendulum result is **Class P4**

For further information, please also find a link to our 'White Paper' containing some explanatory information pertaining to Slip Resistance, and covering off the details for the requirements of the [NCC 2022 Building Code of Australia and AS 4586.2013 – Slip Resistance classification of new pedestrian surface materials](#).

For the **Classic Tredfx PKD443** product, the slip test properties are:

- Reported SRV: 58
- Class: **P5**

This is the slip test report for the actual insert itself, as this is the trafficable surface.

A copy of the Slip Test report is on the following page.

Please also feel free to download a copy of any of our [Product Data Sheets](#) from the website.

*Please note Classic Architectural Group are not licensed Building Surveyors or DDA Consultants, nor do we in any way purport to be. We strongly recommend that you have this product and NCC requirements verified by an accredited party that it is fit for its intended application before installation, including its longevity.*



**classic**  
architectural group



**For Every Step**



A division of Safe Environments Pty Ltd  
www.SafeEnvironments.com.au

4/40 Bessemer Street  
Blacktown NSW 2148  
Phone 02 9621 3706  
ABN 80 118 534 768

4 April 2016

**Test Report No. R8667**  
**Slip Resistance Classification of New Pedestrian Surface Materials**  
AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Tredfx / Classic Architectural  
Client Address: PO Box 126  
Preston VIC 3072  
Product Manufacturer: Supplied by Classic Architectural  
Product Description: Tredfx gritted anti-slip insert product, resin strip with silicon carbide grit surface  
Test conducted according to: AS 4586:2013 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148  
Conducted by: Stuart Lumsden  
Date: 3 March 2016  
Sample: Unfixed  
Rubber slider used: Slider 96  
Slope of specimen: Tested on a flat level surface  
Direction of Test: Perpendicular to ribbed surface  
Temperature: 20°C  
Cleaning: None  
Conditioned: Grade P 400 paper dry followed by wet lapping film

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	59	59	58	57	60

<b>Reported SRV of Sample:</b>	<b>58</b>
<b>Class:</b>	<b>P5</b>



*R. Voorderhake*

Ryan Voorderhake  
Laboratory/Field Technician